

Overview

Our products carry a variety of third party agency approvals. We are continually updating the certifications on our products to maintain the highest level of safety and quality for our customers. The following is a complete listing of approved products, and the certifications they bear. Special inspections and certifications, as well as test data, are available upon request.

Battery Chargers

Battery Charger Listing Overview

PRODUCT LINE	NEMA PE5	CSA	UL	FCC	Seismic
ATevo (1PH) (Style-5054 enclosure)	X	X	X	X	X
ATevo (1PH) (Style-5070 enclosure)	X	X	X		X
AT10.1 (Style-586 enclosure)	X	X	X	X	X
AT10.1 (Style-594 enclosure)	X	X	X	X	X
AT10.1 (Style-5017 enclosure)	X	X	X	X	X
AT10.1 & AT30 (Style-5018 enclosure)	X	X	X	X	X
AT30 (Style-5030 enclosure)	X	X	X	X	X
AT30 (Style-163 enclosure)	X	X	X	X	X
AT30 (Style-198 enclosure)	X	X ¹	X ¹	X	

¹ special factory inspection required

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

Complete Approved Product Listing 3rd PARTY AGENCY APPROVALS

ATEvo (1PH Style-5054 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, UL Std. No. 1564, and UL Std. No. 1012 (certificate # 70030245)

Seismic Standards

- ❖ IEEE 693-2005 (optionally qualified to level high, 0.5g ZPA)
- ❖ IEEE 693-2005 (qualified to level moderate, 0.25g ZPA)
- ❖ California Building Code 2013 (CBC2013)

Emissions

- ❖ FCC Part 15 ¹

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



¹ FCC Part 15 listing pending on ATEvo 1PH Group II (30-100 Adc)

Model Numbers:

- ATEV1024006
- ATEV1024012
- ATEV1024016
- ATEV1024020
- ATEV1024025
- ATEV1048006
- ATEV1048012
- ATEV1048016
- ATEV1048020
- ATEV1048025
- ATEV1130006
- ATEV1130012
- ATEV1130016
- ATEV1130020
- ATEV1130025
- ATEV1260006
- ATEV1260012

- ATEV1024030¹
- ATEV1024040¹
- ATEV1024050¹
- ATEV1048030¹
- ATEV1048040¹
- ATEV1048050¹
- ATEV1130030¹

ATEvo (1PH Style-5070 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, UL Std. No. 1564, and UL Std. No. 1012 (certificate # 70030245)

Seismic Standards

- ❖ IEEE 693-2005 (optionally qualified to level high, 0.5g ZPA)
- ❖ IEEE 693-2005 (qualified to level moderate, 0.25g ZPA)
- ❖ California Building Code 2013 (CBC2013)

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

- ATEV1024075
- ATEV1024100
- ATEV1048075
- ATEV1048100
- ATEV1130040
- ATEV1130050
- ATEV1130075

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

Complete Approved Product Listing 3rd PARTY AGENCY APPROVALS

AT10.1 (Style-586 & Style-594 enclosures)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, UL Std. No. 1564, and UL Std. No. 1012 (certificate # 70030245)

Seismic Standards

- ❖ Zone 4 Seismic Analysis to 1997 Uniform Building Code

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT10012006
AT10012012
AT10012016
AT10012020
AT10012025
AT10024006
AT10024012
AT10024016
AT10024020
AT10024025
AT10048006
AT10048012
AT10048016
AT10048020
AT10048025
AT10130006
AT10130012
AT10130016
AT10130020
AT10130025

AT10.1 (Style-5017 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, and UL Std. No. 1564 (certificate # 70030245)

Seismic Standards

- ❖ Zone 4 Seismic Analysis to 1997 Uniform Building Code

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT10012030
AT10012040
AT10012050
AT10024030
AT10024040
AT10024050
AT10048030
AT10048040
AT10048050
AT10130030

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

Complete Approved Product Listing 3rd PARTY AGENCY APPROVALS

AT10.1 & AT30 (Style-5018 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, and UL Std. No. 1564 (certificate # 70030245)

Seismic Standards

- ❖ IEEE 693-2005 (optionally qualified to level high, 0.5g ZPA)
- ❖ Zone 4 Seismic Analysis to 1997 Uniform Building Code

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT10012075
AT10012100
AT10024075
AT10024100
AT10048075
AT10048100
AT10130040
AT10130050
AT10130075

AT30012050
AT30012075
AT30012100
AT30024050
AT30024075
AT30024100
AT30048050
AT30048075
AT30048100
AT30130025
AT30130030
AT30130040
AT30130050
AT30130075

AT30 (Style-5030 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, and UL Std. No. 1564 (certificate # 70030245)

Seismic Standards

- ❖ IEEE 693-2005 (optionally qualified to level high, 0.5g ZPA)
- ❖ IEEE 693-2005 (qualified to level moderate, 0.25g ZPA)
- ❖ IBC2006

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT30012125
AT30012150
AT30012200
AT30012250
AT30012300
AT30024125
AT30024150
AT30024200
AT30024250
AT30024300
AT30048125
AT30048150
AT30048200
AT30048250
AT30048300
AT30130100
AT30130125
AT30130150
AT30130200

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

Complete Approved Product Listing 3rd PARTY AGENCY APPROVALS

AT30 (Style-163 enclosure)

Safety Listings

- ❖ certified to US & Canadian standards under CAN/CSA- C22.2 No. 107.2-01, and UL Std. No. 1564 (certificate # 70030245)

Seismic

- ❖ IEEE 693-2005 (qualified to level moderate, 0.25g ZPA)

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT30024400
AT30048400
AT30130250
AT30130300
AT30130400

AT30 (Style-163 enclosure)

Safety Listings

- ❖ special CSA or UL *Field Evaluation* available on request

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT30024500
AT30024600
AT30048500

AT30 (Style-198 enclosure)

Safety Listings

- ❖ special CSA or UL *Field Evaluation* available on request

Emissions

- ❖ FCC Part 15

Performance

- ❖ factory certified to NEMA PE5

Environmental

- ❖ NEMA Type-1 (standard)
- ❖ NEMA Type-2 (*drip shield*, available upon request)
- ❖ NEMA Type-4 (*cabinet*, available upon request)

Agencies



Model Numbers:

AT30024800
AT300241K0
AT30048600
AT30048800
AT300481K0
AT30130500
AT30130600
AT30130800
AT301301K0

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

EPIC Console

Overview

PRODUCT LINE	CSA	Seismic	NEMA Type Enclosure
EPIC 2.0	X ¹	X ²	3R
EPIC 1.0	X ¹	X ²	1

¹ special factory or field inspection required

² available upon request

EPIC 2.0 Style-5053 Enclosure (NEMA Type-3R for outdoor use)

Safety Listing

- ❖ special factory or field inspection required to obtain CSA listing

Seismic

- ❖ IEEE 693-2005 (qualified to level *high*, 0.5g ZPA)

Environmental

- ❖ designed to meet IEEE 1635-2012
(ventilation and thermal management of batteries for stationary applications)
- ❖ self-certified to NEMA Type-3R

Agencies

n/a

EPIC 1.0 Style-5047 Enclosure (NEMA Type-1 for indoor use)

Safety Listing

- ❖ special factory or field inspection required to obtain CSA listing

Seismic

- ❖ IEEE 693-2005 (qualified to level *moderate*, 0.25g ZPA)
- ❖ IBC 2006

Environmental

- ❖ self-certified to NEMA Type-1

Agencies

n/a

JF5039-00

(Print Revision 10/30/2019 8:10 AM)

Complete Approved Product Listing 3rd PARTY AGENCY APPROVALS

DC Distribution Panel

Overview

PRODUCT LINE	ETL	UL	CSA	NEMA Type Enclosure
p/n EJ5014-00 (no main breaker)	X	X	X	1
p/n EJ5014-10 (100A main breaker)	X	X	X	1
p/n EJ5014-20 (200A main breaker)	X	X	X	1

Style-5050 enclosure (all models)

Safety Listing

- ❖ ETL certified to UL508A
- ❖ ETL certified to CSA C22.2 No 14-13, Ed. 12

Environmental

- ❖ self-certified to NEMA Type-1

Agencies

