



Intratech Electrical Reports  
12345 Road Drive  
Cityville, California USA 94555  
TEL: ++1-510-555-1212  
FAX: ++1-510-555-1300  
[www.IER.com](http://www.IER.com)

## EN50160 Compliance Report - **PASS**

2011 Calendar Week 43 - 10/24/2011 – 10/30/2011

"Characteristics of Voltage at a Network User's Supply Terminals: Limits and Values"

## PSL Demonstration Unit

George Sample  
Sample Customer  
123 Sample Drive  
Alameda, California 94501 USA  
[www.Sample.com](http://www.Sample.com)

3-phase 4-wire Wye/Star  
277.00V 60Hz

**Summary of Results**  
**EN50160 Compliance**  
**10/24/2011 – 10/30/2011**

**EN50160 Pass-Fail Requirements Table**

EN50160 Section	Power Quality Parameter	EN50160 Compliance	Remarks
4.2.1	Power Frequency	PASS	Coverage 99.90%
4.2.2	Supply Voltage Variations	PASS	Coverage 99.90%
4.2.3	Flicker Severity	PASS	
4.2.4	Voltage Unbalance	PASS	
4.2.5	Harmonic Voltages	PASS	

**EN50160 Additional Information Table**

EN50160 Section	Power Quality Parameter	Remarks
4.2.6	Interharmonic Voltages	Data only
4.2.7	Mains Signaling	Not measured
4.3.1	Interruptions	
4.3.2	Dips	
4.3.3	Swells	
4.3.4	Transient overvoltages	

Note 1: During 10/24/2011 – 10/30/2011 measurements were made 99.90% of the time

Note 2: Low Voltage Systems (< 1 kV) limits were used.

Note 3: Flagged data was excluded from this report.

Instrument used: PQube® ([www.PQube.com](http://www.PQube.com))  
 Manufacturer: Power Standards Lab, U.S.A.  
 PQube ID: PSL Demonstration Unit  
 Location: Main Breaker in Office  
 Serial number: P004424  
 Firmware revision: 2.0.0 2756  
 Calibration Certificate: <http://www.PowerStandards.com/CalibCerts/P004424.pdf>  
 Report Software: PQube Report Writer 2.1  
 Author of Report: Intratech Electrical Reports  
 Name: George Smith

**Customer Information**

Name: George Sample  
 Company: Sample Customer  
 Address 1: 123 Sample Drive  
 Address 2: Alameda, California 94501 USA  
 Address 3:  
 Website: [www.Sample.com](http://www.Sample.com)



*Photo 1 - Sample Caption - Power lines near sample customer*



*Photo 2 - Sample Caption - PQube installation at sample customer*



## EN50160 4.2.1: Power Frequency

**Nominal Frequency:** 60.00Hz

Parameter definition: Mean value of the fundamental frequency measured over 10 seconds

Limitation: For systems with a synchronous connection to an interconnected system

EN50160 Requirement	Measured frequency	Result
99.5% of week: 59.40 Hz - 60.60 Hz	59.96 Hz~60.03 Hz	PASS
100% of week: 56.40 Hz - 62.40 Hz	59.95 Hz~60.04 Hz	PASS



## EN50160 4.2.2: Supply Voltage Variations

**Nominal Voltage:**

277.00V L-N / 480.00V L-L



Parameter definition:



10 minute mean RMS value of the supply voltage

Limitation:

For systems with a synchronous connection to an interconnected system

EN50160 Requirement	Measured L1 Voltage	Measured L2 Voltage	Measured L3 Voltage	Result
95% of week: 249.30V - 304.70V	282.90V~287.25V	282.60V~286.70V	280.90V~285.20V	PASS
100% of week: 235.45V - 304.70V	281.85V~287.85V	281.60V~287.25V	279.65V~285.70V	PASS







### EN50160 4.2.3: Flicker Severity

Parameter definition: Long term flicker severity Plt (2 hour intervals)

Limitation: Under normal operating conditions



EN50160 Requirement	Measured L1 Plt	Measured L2 Plt	Measured L3 Plt	Result
95% of week: $Plt \leq 1$	0.09	0.09	0.10	PASS



## EN50160 4.2.4: Voltage Unbalance

Parameter definition: 10 minute mean RMS values of the negative sequence ratio  $u_2$   
Limitation: Under normal operating conditions

EN50160 Requirement	Measured Unbalance $u_2$	Result
95% of week: 0% ~ 2% $u_2$	0.20%	PASS



## EN50160 4.2.5: Harmonic Voltages

Parameter definition: 10 minute mean RMS values of each individual harmonic voltage  
 Limitation: Under normal operating conditions

**L1-N Harmonics Table**

Odd Harmonics								Even Harmonics			
Not multiples of 3				Multiples of 3							
Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result
H5	6.0%	0.974%	PASS	H3	5.0%	0.478%	PASS	H2	2.0%	0.031%	PASS
H7	5.0%	0.961%	PASS	H9	1.5%	0.115%	PASS	H4	1.0%	0.034%	PASS
H11	3.5%	0.444%	PASS	H15	0.5%	0.094%	PASS	H6	0.5%	0.038%	PASS
H13	3.0%	0.276%	PASS	H21	0.5%	0.029%	PASS	H8	0.5%	0.033%	PASS
H17	2.0%	0.183%	PASS					H10	0.5%	0.026%	PASS
H19	1.5%	0.059%	PASS					H12	0.5%	0.027%	PASS
H23	1.5%	0.043%	PASS					H14	0.5%	0.029%	PASS
H25	1.5%	0.041%	PASS					H16	0.5%	0.026%	PASS
								H18	0.5%	0.026%	PASS
								H20	0.5%	0.027%	PASS
								H22	0.5%	0.026%	PASS

**L2-N Harmonics Table**

Odd Harmonics								Even Harmonics			
Not multiples of 3				Multiples of 3							
Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result
H5	6.0%	1.061%	PASS	H3	5.0%	0.246%	PASS	H2	2.0%	0.030%	PASS
H7	5.0%	0.686%	PASS	H9	1.5%	0.160%	PASS	H4	1.0%	0.035%	PASS
H11	3.5%	0.545%	PASS	H15	0.5%	0.158%	PASS	H6	0.5%	0.032%	PASS
H13	3.0%	0.289%	PASS	H21	0.5%	0.034%	PASS	H8	0.5%	0.033%	PASS
H17	2.0%	0.184%	PASS					H10	0.5%	0.028%	PASS
H19	1.5%	0.051%	PASS					H12	0.5%	0.029%	PASS
H23	1.5%	0.055%	PASS					H14	0.5%	0.029%	PASS
H25	1.5%	0.036%	PASS					H16	0.5%	0.028%	PASS
								H18	0.5%	0.027%	PASS
								H20	0.5%	0.027%	PASS
								H22	0.5%	0.027%	PASS

**L3-N Harmonics Table**

Odd Harmonics								Even Harmonics			
Not multiples of 3				Multiples of 3							
Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result	Order h	EN50160 limit	95% value	Result
H5	6.0%	0.863%	PASS	H3	5.0%	0.275%	PASS	H2	2.0%	0.029%	PASS
H7	5.0%	0.913%	PASS	H9	1.5%	0.103%	PASS	H4	1.0%	0.028%	PASS
H11	3.5%	0.483%	PASS	H15	0.5%	0.067%	PASS	H6	0.5%	0.032%	PASS
H13	3.0%	0.193%	PASS	H21	0.5%	0.028%	PASS	H8	0.5%	0.029%	PASS
H17	2.0%	0.175%	PASS					H10	0.5%	0.026%	PASS
H19	1.5%	0.054%	PASS					H12	0.5%	0.026%	PASS
H23	1.5%	0.050%	PASS					H14	0.5%	0.028%	PASS
H25	1.5%	0.044%	PASS					H16	0.5%	0.027%	PASS
								H18	0.5%	0.026%	PASS
								H20	0.5%	0.026%	PASS
								H22	0.5%	0.026%	PASS

## EN50160 4.2.6: Interharmonic Voltages

Parameter definition:

10 minute mean RMS values of each interharmonic voltage group.

Limitation:

Levels are under consideration in EN50160, but there are no limits at present.

**L1-N Interharmonics Table**

Odd Interharmonics								Even Interharmonics			
Not multiples of 3				Multiples of 3							
Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value
IH5	0.033%	0.046%	0.073%	IH3	0.032%	0.043%	0.056%	IH2	0.031%	0.041%	0.064%
IH7	0.030%	0.040%	0.055%	IH9	0.030%	0.039%	0.066%	IH4	0.032%	0.044%	0.054%
IH11	0.030%	0.040%	0.062%	IH15	0.031%	0.040%	0.062%	IH6	0.032%	0.046%	0.065%
IH13	0.031%	0.042%	0.059%	IH21	0.030%	0.039%	0.057%	IH8	0.030%	0.039%	0.053%
IH17	0.031%	0.040%	0.055%					IH10	0.030%	0.039%	0.055%
IH19	0.031%	0.040%	0.059%					IH12	0.032%	0.041%	0.058%
IH23	0.030%	0.040%	0.048%					IH14	0.031%	0.040%	0.061%
								IH16	0.032%	0.041%	0.070%
								IH18	0.031%	0.040%	0.057%
								IH20	0.031%	0.040%	0.063%
								IH22	0.031%	0.039%	0.060%

**L2-N Interharmonics Table**

Odd Interharmonics								Even Interharmonics			
Not multiples of 3				Multiples of 3							
Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value
IH5	0.034%	0.047%	0.068%	IH3	0.033%	0.045%	0.060%	IH2	0.032%	0.044%	0.062%
IH7	0.032%	0.043%	0.058%	IH9	0.031%	0.041%	0.061%	IH4	0.033%	0.044%	0.061%
IH11	0.032%	0.044%	0.063%	IH15	0.032%	0.043%	0.065%	IH6	0.033%	0.046%	0.062%
IH13	0.033%	0.044%	0.066%	IH21	0.031%	0.041%	0.062%	IH8	0.031%	0.040%	0.059%
IH17	0.032%	0.042%	0.059%					IH10	0.032%	0.042%	0.061%
IH19	0.032%	0.041%	0.056%					IH12	0.034%	0.043%	0.066%
IH23	0.031%	0.041%	0.054%					IH14	0.033%	0.042%	0.066%
								IH16	0.034%	0.045%	0.065%
								IH18	0.032%	0.042%	0.062%
								IH20	0.032%	0.043%	0.059%
								IH22	0.032%	0.041%	0.056%

**L3-N Interharmonics Table**

Odd Interharmonics								Even Interharmonics			
Not multiples of 3				Multiples of 3							
Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value	Order h	Average value	95% value	Max value
IH5	0.031%	0.040%	0.050%	IH3	0.031%	0.041%	0.057%	IH2	0.030%	0.039%	0.056%
IH7	0.030%	0.039%	0.050%	IH9	0.030%	0.038%	0.048%	IH4	0.031%	0.040%	0.049%
IH11	0.030%	0.039%	0.049%	IH15	0.031%	0.040%	0.054%	IH6	0.031%	0.042%	0.060%
IH13	0.031%	0.041%	0.058%	IH21	0.030%	0.039%	0.054%	IH8	0.030%	0.039%	0.054%
IH17	0.030%	0.039%	0.052%					IH10	0.030%	0.038%	0.053%
IH19	0.030%	0.039%	0.051%					IH12	0.032%	0.041%	0.053%
IH23	0.030%	0.039%	0.052%					IH14	0.031%	0.039%	0.056%
								IH16	0.032%	0.041%	0.055%
								IH18	0.030%	0.039%	0.053%
								IH20	0.030%	0.038%	0.054%
								IH22	0.030%	0.039%	0.049%

### **EN50160 4.3.1: Interruptions**

No interruptions during 10/24/2011 – 10/30/2011

### **EN50160 4.3.2: Dips**

No dips during 10/24/2011 – 10/30/2011

### **EN50160 4.3.3: Swells**

No swells during 10/24/2011 – 10/30/2011

### **EN50160 4.3.4: Transient overvoltages**

No transients during 10/24/2011 – 10/30/2011

**Conclusions**  
**EN50160 Compliance**  
**10/24/2011 – 10/30/2011**

**EN50160 Pass-Fail Requirements Table**

EN50160 Section	Power Quality Parameter	EN50160 Compliance	Remarks
4.2.1	Power Frequency	PASS	Coverage 99.90%
4.2.2	Supply Voltage Variations	PASS	Coverage 99.90%
4.2.3	Flicker Severity	PASS	
4.2.4	Voltage Unbalance	PASS	
4.2.5	Harmonic Voltages	PASS	

**EN50160 Additional Information Table**

EN50160 Section	Power Quality Parameter	Remarks
4.2.6	Interharmonic Voltages	Data only
4.2.7	Mains Signaling	Not measured
4.3.1	Interruptions	
4.3.2	Dips	
4.3.3	Swells	
4.3.4	Transient overvoltages	

Note 1: During 10/24/2011 – 10/30/2011 measurements were made 99.90% of the time

Note 2: Low Voltage Systems (< 1 kV) limits were used.

Note 3: Flagged data was excluded from this report.

Instrument used: PQube® ([www.PQube.com](http://www.PQube.com))  
 Manufacturer: Power Standards Lab, U.S.A.  
 PQube ID: PSL Demonstration Unit  
 Location: Main Breaker in Office  
 Serial number: P004424  
 Firmware revision: 2.0.0 2756  
 Calibration Certificate: <http://www.PowerStandards.com/CalibCerts/P004424.pdf>  
 Report Software: PQube Report Writer 2.1  
 Author of Report: Intratech Electrical Reports  
 Name: George Smith

**Customer Information**

Name: George Sample  
 Company: Sample Customer  
 Address 1: 123 Sample Drive  
 Address 2: Alameda, California 94501 USA  
 Address 3:  
 Website: [www.Sample.com](http://www.Sample.com)